



PWSID:	NJ0339314	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	CHATSWORTH ELEMENTARY SCHOOL	System Status:	A
Principal County & City:	BURLINGTON, WOODLAND TWP-0339	System Ownership:	Local govt. or municipal authority
WATER SYSTEM INFORMATION		Source Water Type/Operating Category:	GW

Sample Results for PERFLUORONONANOIC ACID (PFNA)

Result*	Collection Date	Sample #	Analytical Method	Analysis Date	Lab Name (NJ Lab ID)	Date Received
TP001002 (Active)						
<2 NG/L	01/19/2023 / 12:15	810-50933-1	EPA 537	02/01/2023 / 03:36	EUROFINS EATON ANALYTICAL, INC (IN598)	02/04/2023
<2 NG/L	03/25/2022 / 09:45	L2215922-01	EPA 537.1	04/07/2022 / 09:17	ALPHA ANALYTICAL INC (MA015)	04/11/2022
<2 NG/L	09/09/2021 / 13:20	630-21708-1	EPA 537	09/14/2021 / 16:31	LANCASTER LABS INC (PA011)	09/16/2021
<2 NG/L	01/15/2020 / 09:24	L7179040-1	EPA 537	01/21/2020 / 20:18	LANCASTER LABS INC (PA011)	01/27/2020
<2 NG/L	10/22/2019 / 10:56	L7163524-1	EPA 537	10/31/2019 / 22:46	LANCASTER LABS INC (PA011)	11/07/2019
<2 NG/L	09/04/2019 / 09:29	L7137254-1	EPA 537	09/20/2019 / 06:10	LANCASTER LABS INC (PA011)	09/24/2019
<2 NG/L	05/22/2019 / 11:00	L7111197-1	EPA 537	06/01/2019 / 12:19	LANCASTER LABS INC (PA011)	06/06/2019
<0.46 NG/L	03/06/2019 / 10:11	L7095766-1	EPA 537	03/13/2019 / 12:46	LANCASTER LABS INC (PA011)	03/19/2019

\*MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).  
 µg/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
 pCi/L=picocuries of contaminant per liter of water—a curie is a measurement of the rate at which a radioactive material decays.  
 "<" (less than) means the contaminant cannot be accurately detected below the limit specified; the result can be considered zero.

Write any questions/comments to the administrator

Software version number 7.3.17 (11-20-2020)

Mark J. Riether, Lab Director



South Jersey Water Test, LLC  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 856-875-3506 Phone  
 856-875-3507 Fax

www.sjwatertest.com  
 NJDEP Certified Lab # 08006



PWSID:	NJ0339314	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	CHATSWORTH ELEMENTARY SCHOOL	System Status:	A
Principal County & City:	BURLINGTON, WOODLAND TWP-0339	System Ownership:	Local govt. or municipal authority
WATER SYSTEM Test Column Chemical Results Monitoring System Facilities Site Visits Violations Other Data		Source Water Type/Operating Category:	GW
INFORMATION Results		PRINTER FRIENDLY PAGE	

Sample Results for PERFLUOROCTANOIC ACID (PFOA)

Result*	Collection Date	Sample #	Analytical Method	Analysis Date	Lab Name (NJ Lab ID)	Date Received
TP001002 (Active)						
<2 NG/L	01/19/2023 / 12:15	810-50933-1	EPA 537	02/01/2023 / 03:06	EUROFINS EATON ANALYTICAL, INC (IN598)	02/04/2023
<2 NG/L	03/25/2022 / 09:45	12215922-01	EPA 537.1	04/07/2022 / 09:17	ALPHA ANALYTICAL INC (MA015)	04/11/2022
<2 NG/L	09/09/2021 / 13:20	630-21708-1	EPA 537	09/14/2021 / 16:31	LANCASTER LABS INC (PA011)	09/16/2021
<2 NG/L	01/15/2020 / 09:24	L7179040-1	EPA 537	01/21/2020 / 20:18	LANCASTER LABS INC (PA011)	01/27/2020
<2 NG/L	10/22/2019 / 10:56	L7163524-1	EPA 537	10/31/2019 / 22:46	LANCASTER LABS INC (PA011)	11/07/2019
<2 NG/L	09/04/2019 / 09:29	L7137254-1	EPA 537	09/20/2019 / 06:10	LANCASTER LABS INC (PA011)	09/24/2019
<2 NG/L	05/22/2019 / 11:00	L7111197-1	EPA 537	06/01/2019 / 12:19	LANCASTER LABS INC (PA011)	06/06/2019
<0.46 NG/L	03/06/2019 / 10:11	L7095766-1	EPA 537	03/13/2019 / 12:46	LANCASTER LABS INC (PA011)	03/19/2019

\*MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).  
 ug/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
 pCi/L=picocuries of contaminant per liter of water—a curie is a measurement of the rate at which a radioactive material decays.  
 "<" (less than) means the contaminant cannot be accurately detected below the (limit specified) the result can be considered zero.

Software version number 7.3.17 (11-20-2020)

Mark J. Riether, Lab Director



South Jersey Water Test, LLC  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 856-875-3506 Phone  
 856-875-3507 Fax

www.sjwatertest.com  
 NJDEP Certified Lab # 08006



WWSID:	NJ0339314	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	CHATSWORTH ELEMENTARY SCHOOL	System Status:	A
Principal County & City:	BURLINGTON, WOODLAND TWP-0339	System Ownership:	Local govt. or municipal authority
WATER SYSTEM Test Conform	Chemical Results	Monitoring	System Facilities
INFORMATION	Results		Site Visits
			Violations
			Other Data
			PRINTER FRIENDLY
			PAGE

Sample Results for PERFLUOROCTANE SULFONIC ACID (PFOS)

Result*	Collection Date	Sample #	Analytical Method	Analysis Date	Lab Name (NJ Lab ID)	Date Received
TP001002 (Active)						
<2 NG/L	01/19/2023 / 12:15	810-50933-1	EPA 537	02/01/2023 / 03:36	EUROFINS EATON ANALYTICAL, INC (IN598)	02/04/2023
<2 NG/L	03/25/2022 / 09:45	L2215922-01	EPA 537.1	04/07/2022 / 09:17	ALPHA ANALYTICAL INC (AA015)	04/11/2022
<2 NG/L	09/09/2021 / 13:20	630-21708-1	EPA 537	09/14/2021 / 16:31	LANCASTER LABS INC (PA011)	09/16/2021
<2 NG/L	01/15/2020 / 09:24	L7179040-1	EPA 537	01/21/2020 / 20:18	LANCASTER LABS INC (PA011)	01/27/2020
<2 NG/L	10/22/2019 / 10:56	L7163524-1	EPA 537	10/31/2019 / 22:46	LANCASTER LABS INC (PA011)	11/07/2019
<2 NG/L	09/04/2019 / 09:29	L7137254-1	EPA 537	09/20/2019 / 06:10	LANCASTER LABS INC (PA011)	09/24/2019
<2 NG/L	05/22/2019 / 11:00	L7111107-1	EPA 537	06/01/2019 / 12:19	LANCASTER LABS INC (PA011)	06/06/2019
<0.46 NG/L	03/06/2019 / 10:11	L7095766-1	EPA 537	03/13/2019 / 12:46	LANCASTER LABS INC (PA011)	03/19/2019

\*MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).  
 µg/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
 pCi/L=picocuries of contaminant per liter of water—a curie is a measurement of the rate at which a radioactive material decays.  
 "<" (less than) means the contaminant cannot be accurately detected below the limit specified; the result can be considered zero.

Water system's compliance in the watershed

Software version number 7.3.17 (11-20-2020)

Mark J. Riether, Lab Director



South Jersey Water Test, LLC  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 856-875-3506 Phone  
 856-875-3507 Fax

www.sjwatertest.com  
 NJDEP Certified Lab # 08006

NJ0339314



South Jersey Water Test, LLC  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwaterest.com  
 NJ DEP Certification #08006

CHAIN OF CUSTODY RECORD

Customer: Chatsworth Elementary School  
 Contact: Laura Archer  
 Address: 2 John Bowker Jr. Boulevard  
 Chatsworth, NJ 08019  
 Phone: 609-726-1230 x 3  
 Email: larcher@woodlanddoe.org

Lab ID#	Sample Location	Collection Date	Collection Time	Matrix	Field Measurements	No. of Bottles	Pres.	Analysis Required
V12058	Chatsworth Elementary School	11/9/23	12:10	D	Res. Cl = 8005	1 X 120	NaThio	Total Coliform/E.coli
	2 John Bowker Jr. Blvd			D				
	PWS#: NJ0339314							
V12059	B.T	11/9/23	12:15	D		1 X 125	NA	Nitrate
				D		2x250	Trizma	PFNA, PFOA, PFOS*

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time <input checked="" type="checkbox"/> SJWT Standard is 10 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions <input type="checkbox"/> * FRB is only analyzed if there is a hit on PFNA, PFOA, PFOS	Cooler Temp Ice 2.2 °C <input checked="" type="checkbox"/> Properly Preserved <input type="checkbox"/> No
	Received by: <i>[Signature]</i> Date: 11/9/23 Time: 15:16 Received by: _____ Date: _____ Time: _____		

Sampled by: *[Signature]*  
 Relinquished by: *[Signature]*  
 Date: 11/9/23 Time: 15:16  
 Received by: *[Signature]* Date: 11/9/23 Time: 15:16